


# REDUCTION


## ANSI/STD welding concentric and eccentric

### Art. 036.1956 Concentric


### Art. 036.1957 Eccentric



Art. 036.1956



Sec.art. 036.1956



Sec.art. 036.1957

**Execution:** ANSI/STD (Schedule 40) - produced from ASTM A-106 - B Grade seamless pipes - manufacturing, execution and tolerances according to ASTM A-234 and ANSI B 16.9 WPB Grade normatives - featheredge according to ANSI B 16.25 - steel grit sanded surfaces - normalizing thermic treatment.

**On request:** XS execution (Schedule 80) - EN 10204/3.1 B certifications - R.I.N.a and TUV tests - EN 10204/3.1 C certifications.

#### Dimensions

Big R		Small R		H mm	Tolerances H mm	Theoretic weight Kg
R D.	Thickness mm	R d	Thickness mm			
3/4"	2.87	1/2"	2.77	38.10	±1.6	0.07
1"	3.38	1/2"	2.77	50.8	±1.6	0.10
1"	3.38	3/4"	2.87	50.8	±1.6	0.10
1L"	3.56	1/2"	2.77	50.8	±1.6	0.15
1L"	3.56	3/4"	2.87	50.8	±1.6	0.15
1L"	3.56	1"	3.38	50.8	±1.6	0.15
1"	3.68	1/2"	2.77	63.5	±1.6	0.25
1"	3.68	3/4"	2.87	63.5	±1.6	0.27
1"	3.68	1"	3.38	63.5	±1.6	0.27
1"	3.68	1L"	3.56	63.5	±1.6	0.29
2"	3.91	1/2"	2.77	76.2	±1.6	0.39
2"	3.91	3/4"	2.87	76.2	±1.6	0.40
2"	3.91	1"	3.38	76.2	±1.6	0.40
2"	3.91	1L"	3.56	76.2	±1.6	0.43
2"	3.91	1"	3.68	76.2	±1.6	0.45
2"	5.16	1"	3.38	88.9	±1.6	0.68
2"	5.16	1L"	3.56	88.9	±1.6	0.68
2"	5.16	1"	3.68	88.9	±1.6	0.72
2"	5.16	2"	3.91	88.9	±1.6	0.77
3"	5.49	1"	3.38	88.9	±1.6	0.85
3"	5.49	1L"	3.56	88.9	±1.6	0.86
3"	5.49	1"	3.68	88.9	±1.6	0.90
3"	5.49	2"	3.91	88.9	±1.6	0.96
3"	5.49	2"	5.16	88.9	±1.6	1.04
4"	6.02	1"	3.38	101.6	±1.6	1.45
4"	6.02	1L"	3.56	101.6	±1.6	1.50
4"	6.02	1"	3.68	101.6	±1.6	1.54
4"	6.02	2"	3.91	101.6	±1.6	1.63
4"	6.02	2"	5.16	101.6	±1.6	1.72
4"	6.02	3"	5.49	101.6	±1.6	1.77
5"	6.55	2"	3.91	127.0	±1.6	2.62
5"	6.55	2"	5.16	127.0	±1.6	2.66
5"	6.55	3"	5.49	127.0	±1.6	2.72
5"	6.55	4"	6.02	127.0	±1.6	2.81

